

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7120-0065:122 Page 1 of 1

CATEGORY: Annunciators

LISTEE: Faraday Inc, 805 South Maumee St., Tecumseh MI 49286
Contact: Steve A. Blohm (517) 423-2111

DESIGN: Model RDC700 (Cat. No. 401326), RDC-700A (Cat No. 401347), RDC-800 (Cat. No. 401367) and *RDC-800K (Cat No. 401388) remote annunciator unit. The unit contains five operator switches, five indicator lamps and a liquid crystal visual display. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input power: 17 to 26 VDC, 55mA normal standby, 65 mA alarm

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as remote annunciators for use with Model MPC-2000 fire alarm control unit (CSFM Listing No. 7165-0065:123).

*Rev. 07-21-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager